

Report in Accordance with
BS EN ISO 10077-1:2017

**Thermal Performance of
Windows, Doors & Shutters**

Calculation of Thermal Transmittance
Part 1: Simplified Method

CONFIDENTIAL

Report reference: CU18441-1

Issue date: 21 May 2019

Project: 48mm thick door leaf with Liniar LSW016 frame

Prepared for: Future Products Ltd
Enterprise Way
Millennium Business Park
Mansfield
Notts NG19 7JX

Prepared by: Sue Peatey

Build Check Ltd
Montrose House
Lancaster Road
Cressex Business Park
High Wycombe
Bucks HP12 3PY

Tel: 01494 452713 Fax: 0870 210 1013
E-mail: info@buildcheck.co.uk

Notified Body: 1806

This document is confidential and remains the property of Build Check Ltd

Opinions and interpretations expressed herein are outside the scope of UKAS accreditation

The legal validity of this report can only be claimed on presentation of the complete report.

1 Introduction

This document details the thermal performance calculation of the doorset configuration with two glazing units as detailed below.

The frame profile results detailed below are provided by computer simulation using LBL software program THERM 5.2 and validated against proofs in Annex D (D1 to D10) of BS EN ISO 10077-2:2017. The frame profile results detailed below are provided from methods contained in BS EN ISO 10077-1:2017 and in accordance with thermal transmittance requirements detailed in BS EN 14351-1:2006 +A1:2010.

2 Summary of Results

2.1 Centre pane U-Value of glazing calculated in accordance with BS EN 673: 2011

Glazing units	Centre pane U-value (U_g)
Nominal dimensions 4-20-4 90% argon 10% air filled, normal emissivity 0.05 (4mm float, 20mm Superspacer Premium, 4mm Pilkington KS glass)	1.2 W/m ² K
Nominal dimension 6.8-18-4 90% argon 10% air filled, normal emissivity 0.05 (6.8mm laminate float, 18mm Superspacer Premium, 4mm Pilkington KS glass)	1.2 W/m ² K

2.2 Frame thermal transmittance (in accordance with BS EN ISO 10077-1: 2017)

Frame Profile	Frame Thermal Transmittance (U_f)
Head & Threshold	1.3 W/m ² K
Jambs	1.3 W/m ² K
Glazing Cassette (4-20-4 unit)	1.3 W/m ² K
Glazing Cassette (6.8-18-4 unit)	1.3 W/m ² K

2.3 Linear thermal transmittance (in accordance with BS EN ISO 10077-1: 2017)

Frame Profile	Linear Thermal Transmittance (ψ)
Head & Threshold	0.012 W/m.K
Jambs	0.014 W/m.K
Glazing Cassette (4-20-4 unit)	0.040 W/m.K
Glazing Cassette (6.8-20-4 unit)	0.044 W/m.K
Moulding	0.016 W/m.K

2.4 Centre pane U-Value of glazing calculated in accordance with BS EN 673: 2011

Panel build up	Centre Panel U-value (U_p)
Nominally 48mm thick leaf comprising 1.5mm PVC-U facings either side of a 45mm Kerto L core	1.6 W/(m ² ·K)

The legal validity of this report can only be claimed on presentation of the complete report.



2.4 U-Value

The thermal performance of the doorset (U_w) in accordance with EN ISO 10077-1:2017 is:

Doorset with 4-20-4 glazing unit	1.5 W/m²K
Doorset with 6.8-18-4 glazing unit	1.5 W/m²K

All profile calculations based on BS EN ISO 10077-2:2017

3 Authorisation

	Issued by:	Checked by:
Signature:		
Name:	Sue Peatey	Richard Bate
Title:	Laboratory Manager	Technical Director

The legal validity of this report can only be claimed on presentation of the complete report.